

Level sensing relative and absolute pressure transmitter type 712

Pressure range
0 ... 0.3 - 3 bar



The level sensing pressure transmitter Type 712 is manufactured using an relative or absolute pressure measuring cell with an adjusted and amplified sensor signal and is available with various cable lengths from 2 to 30 meters. The Type 712 offers Ex protection as well as versions with integrated temperature measurement.

In addition to voltage and current outputs the Type 712 is available with ratiometric outputs.

- suitable for drinking water
- intrinsically safe execution with voltage- and current output
- suitable for fitting in 1-inch pipe
- with integrated temperature measurement

Technical overview

Pressure range

Relative	0.0 ... 0.3 – 2.5 bar
Absolute	0.8 ... 1.4 – 3.0 bar

Operating conditions

Medium	Fuel oil, ultra-light ¹⁾ Fuel oil, heavy ¹⁾ Diesel oil ¹⁾ Benzine ¹⁾ Drinking water (with EPDM O-ring)	SN 181 160-2 SN 181 160-2
Temperature	Medium and ambient ²⁾ Storage	-20 ... +80 °C -40 ... +80 °C
Overload		3x fs; max. 3 bar at 0.3 bar version

Materials in contact with medium

Case	Stainless steel 1.4404 / AISI 316L
Sensor	Ceramic Al ₂ O ₃
Cable	PE-HD
Protection cover	PPE
Sealing material	FPM, EPDM (for drinking water)

Electrical overview

	Output	Power supply	Load	Current consumption
2 wire	4 ... 20 mA	10 ... 30 VDC	< $\frac{\text{Power supply} - 7\text{V}}{0.02 \text{ A}}$ [Ohm]	< 20 mA
3 wire	0 ... 10 V	12 ... 30 VDC	> 10 kOhm / < 100 nF	< 5 mA
	ratiom. 10 ... 90%	5 VDC ±10%	> 5 kOhm / < 100 nF	< 3 mA
4 wire (with temperature)	ratiom. 10 ... 90%	5 VDC ±10%	> 5 kOhm / < 100 nF	< 3 mA
Polarity reversal protection		Short circuit proof and protected against polarity reversal.		
Oversupply protection		4 ... 20 mA / 0 ... 10 V		36 VDC
Electric strength towards case		ratiom. 10 ... 90 %		6 VDC
Temperature output				500 VDC
				> 1 MΩ

Dynamic response

Response time	< 2 ms
---------------	--------

Runtime

Time starts at the moment of application of minimal supply voltage	< 10 ms
--	---------

Electrical connection

Cable PE-HD length 2, 5, 10, 15, 20, 30 m	Protection standard
---	---------------------

IP 68

Test / Admissions

Electromagnetic compatibility	CE-conform acc. to EN 61326-2-3
UL	ANSI/UL 61010-1 acc. to E325110
Drinking water approval	AC5
Drinking water verification certificate for plastic parts	UBA guidance (KTW and elastomer) W270 WRAS

Ex-protection

IECEx SEV 12.0006	Ex ia IIC T4 Ga
SEV 12 ATEX 0138	II 1 G Ex ia IIC T4 Ga

Weight

Without cable	~ 200 g
---------------	---------

Packaging

Single packaging

Accuracy

Standard

Parameter	Unit	
Max. deviation ³⁾ at 25 °C	% fs	± 0.8
Resolution ⁴⁾	% fs	0.1
Thermal characteristic ^{5), 6)}	% fs/10K	± 0.2
Long term stability acc. IEC EN 60770-1	max.	% fs
		± 0.25

Higher accuracy (only with ratiometric execution and pressure range ≥ 1 bar)

Parameter	Unit	
Max. deviation at compensated temperature range ³⁾ at -10 ... +60 °C	% fs	± 0.5
Resolution	% fs	0.1
Long term stability acc. IEC EN 60770-1	max.	% fs
		± 0.25

¹⁾ Ex-protection to attention!

²⁾ pressure range 0.3 bar < 0.2 % fs


²⁾ non-congealing media

⁵⁾ at -20 ... +80 °C

³⁾ incl. zero point, full scale, linearity, hysteresis and repeatability

⁴⁾ 0.3 bar-type with output 4 ... 20 mA = ± 0.5% fs/10K


Dimensions in mm / Electrical connections



h - Fluid level


► - Measurement reference height

- A - Distance from protection cover to the position of measuring diaphragm
- B - distance from beginning of thread to the position of measuring diaphragm (versions without protection cover)



Device design with explosion protection: 4 ... 20 mA
The grounding connection is conductively connected to the level transmitter housing. The ground conductor of level transmitter must be connected to the equipotential bonding system of the plant.

Device design with explosion protection: ratio m. 10 ... 90%
The electronic GND is connected with a 1MΩ resistor to the level transmitter housing. The GND conductor of level transmitter must be connected to the equipotential bonding system of the plant.




¹⁾ Other pressure range on request

²⁾ Other cable length on request

Accessories

	Order number
Cable hanger	118026
Connection box	118027
Test adapter	118028
Protection cover (pack of 10)	118067
Humidity protection element (pack of 10)	118068
Additional weight	118093
Calibration certificate	104551

Connection box





Additional weight


~200 g

Protection cover

Cable hanger



1) Inside thread ISO 228/1-G 1/4 A



hot-dip galvanized steel –
PA6 glass fibre reinforced

Cable Ø 4.5 ... 6.5

Calculation of level

General level with relative pressure sensor:

$$h = \frac{\Delta p}{\rho \cdot g}$$

General level with absolute pressure sensor:

$$h = \frac{P_{TS} - P_{Baro}}{\rho \cdot g}$$

which $P_{TS} = \frac{U_{TS} - U_{TS_NP}}{U_{TS_EW} - U_{TS_NP}} \cdot (P_{TS_EW} - P_{TS_NP}) + P_{TS_NP}$

and

$$P_{Baro} = \frac{U_{Baro} - U_{Baro_NP}}{U_{Baro_EW} - U_{Baro_NP}} \cdot (P_{Baro_EW} - P_{Baro_NP}) + P_{Baro_NP}$$

Using a second level sensor as barometric air pressure sensor

For level sensor with current output use nominal signal values for $I_{TS} \dots$ instead of variables $U_{TS} \dots$ (resp. $I_{Baro} \dots$ instead of $U_{Baro} \dots$)

Simplification of formula for level sensor with ratiometric output:

$$P_{TS} = \frac{U_{TS} - 0.1 \cdot U_{IN}}{0.8 \cdot U_{IN}} \cdot (P_{TS_EW} - P_{TS_NP}) + P_{TS_NP}$$

$$P_{Baro} = \frac{U_{Baro} - 0.1 \cdot U_{IN}}{0.8 \cdot U_{IN}} \cdot (P_{Baro_EW} - P_{Baro_NP}) + P_{Baro_NP}$$

Using a second level sensor as barometric air pressure sensor

Legend:

h	level [m]	ρ	density of media [kg/m^3]
Δp	measured relative pressure [Pa]	g	acceleration of fall 9.80665 [m/s^2]
P_{TS}	measured pressure of level sensor [Pa]	U_{TS}	signal on level sensor output [V or mA]
P_{BARO}	measured pressure of barometer [Pa]	U_{BARO}	Signal on barometer output [V or mA]
P_{TS_NP}	minimal nominal pressure of level sensor [Pa]	U_{TS_NP}	minimal nominal signal of level sensor [V or mA]
P_{TS_EW}	maximum nominal pressure of level sensor [Pa]	U_{TS_EW}	maximum nominal signal of level sensor [V or mA]
P_{BARO_NP}	minimal nominal pressure of barometer [Pa]	U_{BARO_NP}	minimal nominal signal of barometer [V or mA]
P_{BARO_EW}	maximum nominal pressure of barometer [Pa]	U_{BARO_EW}	maximum nominal signal of barometer [V or mA]

Specification temperature output



$$T_{TEMP} = T_0 + 1 \left(\left(a + b \cdot \ln \left(R \cdot \left[\frac{U_{IN}}{OUT T} - 1 \right] \right) \right) + c \cdot \ln \left(R \cdot \left[\frac{U_{IN}}{OUT T} - 1 \right]^3 \right) \right) \frac{T_{TEMP}}{T_0}$$

Temperature NTC [°C]
-273.15 [°C]

OUT T	Voltage NTC [V]
R	20'000 [Ω]
U_{IN}	4.5 ... 5.5 [V]

a = 0.001204001
b = 0.000208775
c = 0.000000294

$$T_{TEMP} = f(OUT T)$$



**Huba Control AG
Headquarters**
Industriestrasse 17
5436 Würenlos
Telefon +41 (0) 56 436 82 00
Telefax +41 (0) 56 436 82 82
info.ch@hubacontrol.com

**Huba Control AG
Niederlassung Deutschland**
Schlattgrabenstrasse 24
72141 Walddorfhäsach
Telefon +49 (0) 7127 23 93 00
Telefax +49 (0) 7127 23 93 20
info.de@hubacontrol.com

**Huba Control SA
Succursale France**
Rue Lavoisier
Technopôle Forbach-Sud
57602 Forbach Cedex
Téléphone +33 (0) 387 847 300
Télécopieur +33 (0) 387 847 301
info.fr@hubacontrol.com

**Huba Control AG
Vestiging Nederland**
Hamseweg 20A
3828 AD Hoogland
Telefoon +31 (0) 33 433 03 66
Telefax +31 (0) 33 433 03 77
info.nl@hubacontrol.com

**Huba Control AG
Branch Office United Kingdom**
Unit 13 Berkshire House
County Park Business Centre
Shrivenham Road
Swindon Wiltshire SN1 2NR
Phone +44 (0) 1993 776667
Fax +44 (0) 1993 776671
info.uk@hubacontrol.com

www.hubacontrol.com